

Sample Number	Sample Labeling	Sampling Date	Test Required
---------------	-----------------	---------------	---------------

Sampling Site Information

Air Quality in Control Chamber

HKIEQ15-00098.001	Initial	2 July 2015	Total Bacteria Count
HKIEQ15-00098.002	2 nd hour	2 July 2015	Total Bacteria Count
HKIEQ15-00098.003	8 th hour	2 July 2015	Total Bacteria Count

Test Method

Total Bacteria Count : TSA agar was used and incubated at 30-35 °C no less than 2 days.

Unit Sample information provided by client

Production Description : Ceiling Mounted Germicidal UV Troffer
 Model No. : Puralizer PR-UV01
 Country of Origin : China

Set up Information

Test request : Total Bacteria Count
 Size of Control Chamber : Approx. 30m³
 Ventilation : With internal ventilation
 Treatment Duration : Total 8 hours
 Volume sampled : HKIEQ15-00098.001: 200L
 : HKIEQ15-00098.002: 200L
 : HKIEQ15-00098.003: 300L

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only except perishable samples.